



Sanitary Sewer Overflow Annual Report

Division of Surface Water

Date: 1/9/2016
Facility name: Village of Coldwater WWTP
Ohio NPDES permit no.: 2PB00013*ID
Period covered by report: November 1 2014-October 31 2019

Contact person

Name: Donald R Bruns
Title: Wastewater Superintendent
Mailing address: 610 W. Sycamore St.Coldwater, Ohio 45828
Telephone: (419)678 - 4881
Email: cwwp@villageofcoldwater.com

Certification:

I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.

Name Donald R Bruns **Title:** Wastewater Superintendent
(typed): _____

Signature: _____ **Date:** _____

SSO Annual Report Table 1: SSO Identification		Ohio NPDES Permit No.:2PB00013*ID	
Identification No. ^A	Location Description	Receiving Water ^B	Eliminated ^C
301	E. Vine St.& N. 7 th St.	SS to Coldwater Creek	
302	S. 7 th St. at Alley	SS to Coldwater Creek	
303	E. end of E. College at Alley	SS to Coldwater Creek	
304	S end of S. Wilson at Alley	SS to Hardin Creek	
305	Alley between W. Vine & W. Butler	SS to Hardin Creek	

- A. Assign each SSO location a unique identification by numbering them consecutively, beginning with 301.
- B. Enter name of receiving water. If an SSO enters a storm sewer, enter “SS to (name of receiving water).” If an SSO does not reach a receiving water, enter (None”).
- C. If an SSO has been eliminated, enter the date of elimination (MM/DD/YY).

SSO Annual Report Table 2: SSO Event Information			Ohio NPDES Permit No.:2PB00013*ID
Date ^A	Identification No. ^B	Receiving Water ^C	Volume ^D
3/14/15	302	Coldwater Creek	.002
3/14/15	304	Hardin Creek	.010
3/26/15	304	Hardin Creek	.008
4/8/15	302	Coldwater Creek	.001
4/8/15	304	Hardin Creek	.008
4/9/15	302	Coldwater Creek	.013
4/9/15	304	Hardin Creek	.022
5/16/15	302	Coldwater Creek	.006
5/16/15	304	Hardin Creek	.008
5/31/15	302	Coldwater Creek	.074
5/31/15	304	Hardin Creek	.126
5/31/15	305	Hardin Creek	.048
6/12/15	304	Hardin Creek	.010
6/14/15	302	Coldwater Creek	.028
6/14/15	304	Hardin Creek	.037
6/14/15	305	Hardin Creek	.020
6/15,16/15	302	Coldwater Creek	.231
6/15,16/15	303	Coldwater Creek	.045
6/15,16/15	304	Hardin Creek	.425
6/15,16/15	305	Hardin Creek	.743
6/17/15	302	Coldwater Creek	.391
6/17/15	303	Coldwater Creek	.278
6/17/15	304	Hardin Creek	.812
6/17/15	305	Hardin Creek	.990
6/26,27/15	302	Coldwater Creek	.097
6/26,27/15	303	Coldwater Creek	.050
6/26,27/15	304	Hardin Creek	.220
6/26,27/15	305	Hardin Creek	.108
7/7/15	302	Coldwater Creek	.055
7/7/15	303	Coldwater Creek	.015
7/7/15	304	Hardin Creek	.184
7/7/15	305	Hardin Creek	.192

A. Enter date as “MM/DD/YY”. Enter “Various” to summarize overflows of less than 1000 gallons from an SSO location

B. Enter the unique identification assigned in Table 1.

C. Enter name of receiving water. If an SSO enters a storm sewer, enter “SS to (name of receiving water).” If an SSO does not reach a receiving water, enter “None”.

D. Enter estimate of volume in MG (million gallons). Enter estimate of total volume if summarizing data.

Use additional pages as needed.

SSO Annual Report Table 2: SSO Event Information			Ohio NPDES Permit No.:2PB00013*ID
Date ^A	Identification No. ^B	Receiving Water ^C	Volume ^D
7/12/15	302	Coldwater Creek	0.007
7/12/15	304	Hardin Creek	0.019
7/14/15	301	Coldwater Creek	0.018
7/13,14/15	302	Coldwater Creek	0.062
7/13,14/15	303	Coldwater Creek	0.020
7/14/15	304	Hardin Creek	0.056
7/13,14/15	305	Hardin Creek	0.190
7/18/15	302	Coldwater Creek	0.022
7/18/15	305	Hardin Creek	0.022
7/19/15	301	Coldwater Creek	0.019
7/19/15	302	Coldwater Creek	0.071
7/19/15	304	Hardin Creek	0.057
7/19/15	305	Hardin Creek	0.252
9/19/15	302	Coldwater Creek	.008
9/19/15	304	Hardin Creek	.006
9/19/15	305	Hardin Creek	.006
10/28/15	302	Coldwater Creek	.005
10/28/15	304	Hardin Creek	.002
12/27/15	302	Coldwatert Creek	.078
12/27/15	304	Hardin Creek	.034
12/27/15	305	Hardin Creek	.179
12/28/15	302	Coldwater Creek	.011
12/28/15	304	Hardin Creek	.009

- A. Enter date as "MM/DD/YY". Enter "Various" to summarize overflows of less than 1000 gallons from an SSO location
- B. Enter the unique identification assigned in Table 1.
- C. Enter name of receiving water. If an SSO enters a storm sewer, enter "SS to (name of receiving water)." If an SSO does not reach a receiving water, enter "None".
- D. Enter estimate of volume in MG (million gallons). Enter estimate of total volume if summarizing data.

Use additional pages as needed.

SSO Annual Report Table 3: Water in Basement Occurrences

Ohio NPDES Permit No.:2PB00013*ID

Sewershed ^A	WIB Occurrences ^B	Causes ^C
Plum Drive	7	W
East Plum,Elizabeth,North	7	W
Emerald Ave.	3	W,D
N. Cedar, W. Butler	9	W,D
E.Sycamore	3	W, B
W. Walnut,W. Main	3	W
Westview, Mary Lane	3	W
E. Walnut	8	W
Miscellaneous	17	W
Total Occurrences	60	

- A. A sewershed is a specific geographic area, such as a city block or a subdivision, that drains to a common outlet.
- B. Enter the total number of water in basement occurrences report for the sewershed.
- C. Enter all causes that apply: W = extreme weather; E = equipment failure; P = power failure; D = debris in line; R = roots; G = grease; B = other blockages; L = Line deterioration; V = vandalism; O = other, prove details.

Use additional pages as needed.

Enter narrative analysis of WIB patterns by location, frequency and cause.

All of our WIB Occurences happened between June 14th and June 18th. everything was saturated from the 3 previous days of rain totaling 2.54" then on the 17th we got another 3 plus inches most of it in a couple hours time causing flooding everywhere, streets were full backyards flooded a lot of sanitary manholes were under water from flooding. All the creeks were out of their banks. In the N. Cedar W. Butler area we discovered an abstruction in a manhole on a 12" line. This also could of affected Emerald Ave. The rest was just so much water and no where for it to go.